

## Technician Job Report

Foundry Lane, Smethwick, West Midlands, B66 2LP  
 Telephone : 0845 900 22 44  
 Web Site : [www.averyweigh-tronix.com](http://www.averyweigh-tronix.com)

### Site Details:

Trent Valley Kart Club  
 P F International Kart Circuit  
 Brandon  
 GRANTHAM  
 NG32 2AY

Service Order No	241010173
Site Contact	John Woodcock/Lesley Richard
Quoted Price	
Customer Order No	
User Neglect or Damage	No
Calibration Certificate Issued	None
Technician	Whitworth M R

### Machine Details:

Machine Details	Manufacturer	Asset No	Department	Capacity & Units
ZM305:220760717	Avery Weigh-Tr	ZM305:220760717	EXPRESS ASPHALT	0

### Description Of Work:

Calibration of one x dormant weighscale.

In the case of work under a service agreement. Avery Weigh-Tronix Service Agreement Terms and Conditions will apply, including clauses 3 and 13. In the case of work undertaken not under a service agreement, Avery Weigh-Tronix General Terms and Conditions will apply, in particular clauses 3 & 5. Copies of these terms are attached if you requested them at the time of the visit and can be provided at any time upon request.

The above work was completed to the customer's satisfaction as confirmed by the customer below, and the customer confirmed that, if applicable, all invoices in respect of such work shall be paid immediately upon receipt.

Customer Name :

Date : 29/07/2024 00:00

## Calibration Certificate

Avery Weigh-Tronix  
 Foundry Lane, Smethwick  
 West Midlands, B66 2LP  
[www.averyweigh-tronix.com](http://www.averyweigh-tronix.com)  
**Tel:** 0845 900 22 44

### Customer Details

Name : Trent Valley Kart Club  
 Address : Brandon  
  
 Grantham  
 NG32 2AY

Contact Name : John Woodcock/Lesley Richardso  
 Telephone No. 07883401205

### Linearity / Accuracy Test

Test Point	As Found Reading	As Found Deviation	Definitive Reading	Definitive Deviation
0.0 kg	0.0 kg	0.0 kg	0.0 kg	0.0 kg
120.0 kg	120.0 kg	0.0 kg	120.0 kg	0.0 kg
240.0 kg	240.0 kg	0.0 kg	240.0 kg	0.0 kg
360.0 kg	360.0 kg	0.0 kg	360.0 kg	0.0 kg
480.0 kg	480.0 kg	0.0 kg	480.0 kg	0.0 kg
600.0 kg	600.0 kg	0.0 kg	600.0 kg	0.0 kg

**Certificate No. 241010173/0101**

**Date of Calibration :** 30/07/2024  
**Next Calibration Due :** Jul 2025

### Agreement No.

Location : GRANTHAM  
 Department : EXPRESS ASPHALT  
 Plant Number : Scale  
 Manufacturer : Avery Weigh-Tronix  
 Model : ZM305  
 Serial No : 220760717  
 Capacity : 600 kg  
 Resolution : 0.2 kg  
 Tolerance : +/-0.6  
 Calibration Frequency :

### Off Centre 2 3 or End -Middle-End Loading Test 1 4 1-2-3

Test Point	As Found Reading	As Found Deviation	Definitive Reading	Definitive Deviation
250.0 kg	250.0 kg	0.0 kg	250.0 kg	0.0 kg
250.0 kg	250.0 kg	0.0 kg	250.0 kg	0.0 kg
250.0 kg	250.0 kg	0.0 kg	250.0 kg	0.0 kg
250.0 kg	250.0 kg	0.0 kg	250.0 kg	0.0 kg

### Test Weight Details

Weight Set No. & Certificate No.

T060:UK230576  
 T180:UK230584

Test weights and equipment are traceable to national standards.

### Repeatability Test

Test Point	As Found Reading	As Found Deviation	Definitive Reading	Definitive Deviation
500.0 kg	500.0 kg	0.0 kg	500.0 kg	0.0 kg
500.0 kg	500.0 kg	0.0 kg	500.0 kg	0.0 kg
500.0 kg	500.0 kg	0.0 kg	500.0 kg	0.0 kg

This certificate complies with the United Kingdom Weighing Federation Calibration Code of Practice for non-automatic weighing instruments.

### Comments

Make-up weight used.

### Tolerances

Unless otherwise agreed tolerances will be those permitted by current Weights and Measures Regulations for Class III machines as follows:

0-500 divisions +/- 1 divn.  
 >500-2000 divisions +/- 2 divn.  
 >2000 divisions +/- 3 divn.

For key calibration information please login to <https://averyweigh-tronix.com>

Technicians Name: Whitworth M R

Technicians Signature: 

### 1. CERTIFICATES AND TOLERANCES

Measurements will be recorded over the equipment's working range and a Certificate of Calibration provided (hereafter referred to as Certificate) showing performance to a specified tolerance. Unless otherwise agreed, tolerances will be those permitted by current Weights and Measures Regulations for Class III machines in relation to the obliteration of stamps as follows: 0 to 500 divisions = +/- 1 division, >500 to 2000 divisions = +/- 2 divisions, > 2000 divisions = +/- 3 divisions.

### 2. AS FOUND CERTIFICATE

An 'As Found' test will be conducted without any prior adjustments and/or repair being made apart from usual preparations for weighing such as Zero balancing or levelling carried out in accordance with the customer's normal operating procedures.

### 3. DEFINITIVE CERTIFICATE

A 'Definitive' test is usually carried out after the necessary adjustments have been made. If any required adjustments and/or repairs are covered by a Service Agreement they will be carried out prior to the Definitive Test. If the equipment requires work not covered by a Service Agreement, Avery Weigh-Tronix will quote for any rectification work required and will give the customer the option to suspend the definitive test until such work has been carried out. Avery Weigh-Tronix reserves the right to charge for additional costs incurred if a test is suspended for any reason outside of their control.

### 4. ADJUSTMENTS AND REPAIRS

The Calibration Service does not cover adjustments and repair to equipment, though necessary adjustments may be covered by a Service Agreement.

### 5. TRACEABILITY

The Test Weights used are traceable to National Standards of Mass. The appropriate certificates for the Test Weights used will be quoted on the Certificate. Traceability implies that there is an unbroken chain back to National Physical Laboratory Standards of Mass. For Avoirdupois (Imperial) machines, these may be calibrated with metric weights assuming a conversion factor of 1lb. = 453.59237g.

### 6. MEASUREMENTS TAKEN

(1) Unless otherwise agreed, pre-determined measurement points will be selected, normally, these will be a reading at zero and four to ten other readings in the equipment's range. In the case of equipment with a capacity in excess of 250kg, or with restricted platform sizes it may be necessary to use 'make-up' weights. This does not affect the validity of the test. Where possible weighbridges will be tested up to the maximum gross vehicle weight allowed under current legislation (without dispensation).

(2) Off Centre loading (if applicable): Up to four readings will be taken, normally at about one quarter to half of the instruments capacity, at various off centre points. For machines which weigh rolling loads (e.g. overhead track scales and weighbridges) the test may be carried out by placing the load at the beginning, middle and end of the load receptor.

(3) Repeatability: Three readings (at the same test point) will be taken normally at a load value of 25% or more of the instruments capacity.

Note! 'Make up' loads may in some cases be used for Off Centre loading and Repeatability tests and this will not affect the validity of the results.

(4) Avery Weigh-Tronix standard calibration service is carried out in line with internal procedures relevant to the instrument and complies with the UK Weighing Federation Calibration Code of Practice.

### 7. ENVIRONMENT

Unless otherwise specified, the Calibration Service will be carried out on the equipment in its normal location and in the environment as found.

### 8. CARTAGE OF TEST WEIGHTS

For all tests of machines having a capacity in excess of 750kg, the customer is responsible for the cartage of test weights from and to Avery Weigh-Tronix premises. Unless otherwise specified, for road weighbridges being calibrated to a capacity in excess of 10,000kg the Calibration Service includes the provision of a Weighbridge Test Unit.

### 9. UNSKILLED LABOUR AND LIFTING EQUIPMENT

The customer is responsible for supplying unskilled labour, lifting and handling equipment for the movement of Test Weights on site.

### 10. HANDLING OF TEST WEIGHTS

The customer is responsible for any damage caused to Test Weights whilst they are on the customer's premises (or being transported by the customer), except to the extent that such damage arises from the negligence of an employee of Avery Weigh-Tronix or its sub-contractor or agent.

### 11. ACCURACY

The certificate issued under this service is based on readings taken at a particular point of time and a particular location. It does not guarantee the accuracy of the equipment in the future. The interpretation of the results declared is the responsibility of the customer having regard to the nature of the machine use.

### 12. UKAS CERTIFICATES

Should a customer require a calibration service, which complies with the requirements of UKAS / ISO17025, this can be arranged; however this will be on a specific UKAS contract with different terms, conditions and documentation.

### 13. EQUIPMENT OUTSIDE THE TOLERANCE

If a calibration is carried out, a certificate may still be issued even if a machine is outside of the prescribed tolerance (ref point 11).

### 14. NOTIFICATION PROCEDURE

To comply with the relevant Weights and Measures Regulations it is a legal requirement that users of weighing equipment notify their Local Trading Standards Department when a major adjustment or component change is made which could affect the metrological performance of the machine.

### 15. MEASUREMENT UNCERTAINTY

Where there is zero error shown for repeatability, Measurement Uncertainty can normally be considered to be within approximately +/- one scale division or where the resolution is  $\leq 0.0001$ g approximately +/- six scale divisions. Should a calculation for Measurement Uncertainty be required this would only be supplied with a UKAS calibration contract.

### 16. TERMS AND CONDITIONS

Where calibration work is carried out as part of a Service Agreement Avery Weigh-Tronix's Service Agreement Terms and Conditions shall apply. Where calibration work is carried out as an addition to a Service Agreement or in the absence of a Service Agreement then Avery Weigh-Tronix's General Terms and Conditions shall apply. Copies of the applicable terms have been made available to customer and further copies are available upon request.